

5. Analysis and Concepts Under Consideration

Water Quality
Standards Task Force

February 8, 2018

Ken Seasholes

Manager, Resource Planning & Analysis
Central Arizona Project

PROTECT
LAKE MEAD



CAP
CENTRAL ARIZONA PROJECT


Considerations for WQ Analysis

- Characteristics of the introduced non-Project Water supplies
 - Volumes
 - Timing
 - Location
 - Water quality "profile"
- Status of the Colorado River supply & recovery
 - Shortage reductions and direct recovery volumes
- Characteristics of the CAP system
 - Physical characteristics
 - Distribution of demands and associated flow rates

- Goal was to develop a tool to analyze and visualize how introduced water supplies could affect water quality in the CAP system


- [illegible]

- Annual time step
- The CAP system is divided into 11 approximately equal zones
- Full mixing within a zone
- Assumes the relative distribution of future demands is similar to current demands
 - Alternate scenarios are possible
 - Supplies can “move” upstream through exchange





Modeling Steps

- Define water quality parameters for introduced supplies
 - Can be based on known or speculative supply types
- Create non-Project water supply scenarios
 - Volume, by supply type, by zone
- Select CAP supply volume
- Select specific constituent for mapping



Scenario: B. Scottsdale Only

CO River Supply: Normal; 3,000 AF from Harquahala





		Concentration										
Delivery Month	Zone	1	2	3	4	5	6	7	8	9	10	11
		BSH	LHQ	P01A MA	HSY	Wad	CSIP	P01AM A	TusAM A	Mar	Tus	Term
5	Arsenic ug/l	3.30	3.30	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35	3.35
0.7	Fluoride mg/l	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
1	Nitrate mg/l	0.10	0.10	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11
723	TDS mg/l	649	649	650	650	650	650	650	650	650	650	650
4	TOC mg/l	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20
6	Turbidity NTU	1.48	1.48	1.48	1.48	1.48	1.48	1.48	1.48	1.48	1.48	1.48

Percent of Delivery Maximum												
Constituent	BSH	LHQ	PHKA MA	HSY	Wad	CSIP	PHKAM A	TusAM A	Mar	Tus	Term	
Arsenic ug/l	66%	66%	67%	67%	67%	67%	67%	67%	67%	67%	67%	
Fluoride mg/l	14%	14%	14%	14%	14%	14%	14%	14%	14%	14%	14%	
Nitrate mg/l	30%	30%	31%	31%	31%	31%	31%	31%	31%	31%	31%	
TDS mg/l	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	
TOC mg/l	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	
Turbidity NTU	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	

Percent of Mixing Capacity Utilized												
Constituent	BSH	LHQ	PIXA MA	HSY	Wad	CSIP	PIAAM	TunAM	Mar	Tun	Term	
Arsenic ug/l	0%	0%	3%	3%	3%	3%	3%	3%	3%	3%	3%	
Fluoride mg/l	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Nitrate mg/l	0%	0%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
TDS mg/l	0%	0%	1%	1%	1%	1%	1%	1%	1%	1%	1%	
TOC mg/l	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Turbidity NTU	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	

Scenario: D. High Arsenic and Nitrate, Plus SRP

CO River Supply: Normal; 3k Scottsdale; 15k arsenic wsest; 7.5 k arsenic mid; 3k arsenic south




		Concentration										
Delivery Month	Zone	1	2	3	4	5	6	7	8	9	10	11
		BSH	LHQ	P01A MA	HSY	Wad	CSIP	P01AM A	TusAM A	Mar	Tus	Term
5	Arsenic ug/l	3.30	3.46	3.52	3.52	3.61	3.61	3.86	3.86	3.86	3.86	3.86
0.7	Fluoride mg/l	0.10	0.16	0.16	0.16	0.19	0.19	0.19	0.19	0.19	0.19	0.19
1	Nitrate mg/l	0.10	0.14	0.15	0.15	0.23	0.23	0.41	0.41	0.53	0.53	0.53
723	TDS mg/l	649	659	659	659	659	659	661	661	661	661	661
4	TOC mg/l	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20
6	Turbidity NTU	1.48	1.47	1.47	1.47	1.46	1.46	1.85	1.85	1.85	1.85	1.85

Percent of Delivery Maximum													
Constituent	BSH	LJC	P01A	MA	HSY	Wad	CSIP	P01AM	A	TusAM	Mar	Tus	Term
Arsenic ug/l	66%	63%	70%	70%	72%	72%	77%	77%	77%	77%	77%	77%	77%
Fluoride mg/l	14%	23%	23%	23%	27%	27%	27%	27%	27%	27%	27%	27%	27%
Nitrate mg/l	10%	14%	15%	15%	23%	23%	41%	41%	53%	53%	53%	53%	53%
TDS mg/l	90%	91%	91%	91%	91%	91%	91%	91%	91%	91%	91%	91%	91%
TOC mg/l	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%
Turbidity NTU	25%	25%	25%	25%	24%	24%	37%	37%	37%	37%	37%	37%	37%

Percent of Mixing Capacity Utilized											
Constituent	BSH	LHQ	P01A MA	HSY	Wad	CSIP	P01AM A	TusAM A	Mar	Tus	Term
Arsenic ug/l	0%	9%	13%	13%	16%	16%	33%	33%	33%	33%	33%
Fluoride mg/l	0%	10%	10%	10%	15%	15%	15%	15%	15%	15%	15%
Nitrate mg/l	0%	4%	6%	6%	14%	14%	34%	34%	48%	48%	48%
TDS mg/l	0%	14%	14%	14%	14%	14%	16%	16%	16%	16%	16%
TOC mg/l	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Turbidity NTU	0%	0%	0%	0%	0%	0%	8%	8%	8%	8%	8%

Scenario: D. High Arsenic and Nitrate, Plus SRP

CO River Supply: 1/3 Reduction; 3k Scottsdale; 15k arsenic wsest; 7.5 k arsenic mid; 3k arsenic south





		Concentration											
		Zone	1	2	3	4	5	6	7	8	9	10	11
Delivery Max	Constituent	BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term	
5	Arsenic ug/l	3.30	3.55	3.62	3.62	3.75	3.75	4.11	4.11	4.10	4.10	4.10	
0.7	Fluoride mg/l	0.10	0.19	0.19	0.19	0.24	0.24	0.22	0.22	0.22	0.22	0.22	
723	Nitrate mg/l	0.10	0.16	0.16	0.16	0.23	0.23	0.55	0.55	0.72	0.72	0.72	
4	TDS mg/l	649	664	664	664	664	664	666	666	666	666	666	
4	TOC mg/l	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	
6	Turbidity NTU	1.48	1.46	1.46	1.46	1.45	1.45	2.02	2.02	2.01	2.01	2.01	

		Percent of Delivery Maximum										
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
Constituent	Delivery Max	BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
5	Arsenic ug/l	66%	75%	72%	72%	75%	75%	82%	82%	82%	82%	82%
0.7	Fluoride mg/l	14%	27%	27%	27%	34%	34%	31%	31%	31%	31%	31%
1	Nitrate mg/l	10%	16%	16%	16%	23%	23%	55%	55%	72%	72%	72%
723	TDS mg/l	90%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%
4	TOC mg/l	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%
6	Turbidity NTU	25%	24%	24%	24%	24%	24%	34%	34%	34%	34%	34%

		Percent of Mixing Capacity Utilized										
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
Constituent	Delivery Max	BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
5	Arsenic ug/l	0%	15%	15%	15%	26%	26%	48%	48%	47%	47%	47%
0.7	Fluoride mg/l	0%	15%	15%	15%	23%	23%	20%	20%	20%	20%	20%
1	Nitrate mg/l	0%	7%	7%	7%	21%	21%	50%	50%	69%	69%	69%
723	TDS mg/l	0%	20%	20%	20%	20%	20%	23%	23%	23%	23%	23%
4	TOC mg/l	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
6	Turbidity NTU	0%	0%	0%	0%	-1%	-1%	12%	12%	12%	12%	12%

Scenario: 300k mcl

CO River Supply: Normal; Only Project Water




		Concentration											
		Zone	1	2	3	4	5	6	7	8	9	10	11
Delivery Max	Constituent	BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	TusA AM	Mar	Tus	Term	
5	Arsenic ug/l	3.30	3.72	3.77	3.77	4.18	4.18	4.42	4.42	5.36	5.36	5.36	
0.7	Fluoride mg/l	0.10	0.34	0.34	0.34	0.58	0.58	0.73	0.73	1.28	1.28	1.28	
1	Nitrate mg/l	0.10	0.72	0.73	0.73	1.34	1.34	1.70	1.70	3.63	3.63	3.63	
723	TDS mg/l	649	640	640	640	631	631	625	625	604	604	604	
4	TOC mg/l	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	3.20	
6	Turbidity NTU	1.48	1.39	1.39	1.39	1.30	1.30	1.24	1.24	1.03	1.03	1.03	

		Percent of Delivery Maximum										
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
Constituent	Delivery Max	BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
5	Arsenic ug/l	66%	74%	75%	75%	84%	84%	88%	88%	107%	107%	107%
0.7	Fluoride mg/l	14%	43%	43%	43%	83%	83%	104%	104%	183%	183%	183%
1	Nitrate mg/l	10%	72%	73%	73%	134%	134%	170%	170%	####	####	####
723	TDS mg/l	90%	89%	89%	89%	87%	87%	86%	86%	84%	84%	84%
4	TOC mg/l	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%
6	Turbidity NTU	25%	23%	23%	23%	22%	22%	21%	21%	17%	17%	17%


		Percent of Mixing Capacity Utilized										
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
Constituent	Delivery Max	BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
		BSH	LQ	PMA MA	HSY	Wad	CSIP	PMA A	Tusa A	Mar	Tus	Term
5	Arsenic ug/l	0%	25%	28%	28%	52%	52%	66%	66%	121%	121%	121%
0.7	Fluoride mg/l	0%	40%	40%	40%	80%	80%	105%	105%	197%	197%	197%
1	Nitrate mg/l	0%	63%	70%	70%	138%	138%	178%	178%	####	####	####
723	TDS mg/l	0%	-12%	-12%	-12%	-24%	-24%	-32%	-32%	-61%	-61%	-61%
4	TOC mg/l	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
6	Turbidity NTU	0%	-2%	-2%	-2%	-4%	-4%	-5%	-5%	-10%	-10%	-10%

Role of the Model

- The model is a helpful tool for evaluating future scenarios and policy options
- It can provide *insights* into the policy choices, but does not *determine* policy choices
 - The policy choices themselves have many other dimensions (e.g., equity, risk, etc.)
 - One potentially useful insight has to do with the relationship between the current water quality and the “point of delivery” standards from the Stakeholder proposal




Comparison Chart



Based on revised Stakeholder Proposal

Current vs. Delivery Max




Mixing Capacity

- Ideally, water quality standards/program would sustainably manage that mixing capacity
 - Allow benefits of mixing (i.e., cost savings for reduced treatment)
 - Ensure that mixing capacity is available for later projects
- *Is there an analytical way to determine the “sweet spot”?*
 - One approach is to consider a “buildout” scenario


Buildout Scenario

- What “composite” supply results in 100% of the mixing capacity being used when the last non-Project supply is introduced?
- This can be determined analytically, provided the following two questions are addressed:
 - What is the maximum realistic volume of introduced supplies?
 - How are those supplies distributed along the CAP system?



Buildout Scenario

- The primary *insight* that is gained has to do with how tight or loose each of the parameters is
- By themselves, the numbers are not suitable for direct translation into introduction standards, but they can help inform the discussion of tradeoffs



www.CentralArizonaProject.com
www.CAGRD.com
www.ProtectLakeMead.com

1968-2018
CENTRAL ARIZONA PROJECT